

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0801:164 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski (585) 223-4060 Fax (585) 421-4263

DESIGN: Model D286 ionization type smoke detector. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 10-30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as ionization smoke detector for use with separately listed compatible fire alarm control units. Unit is intended for use with Model D287, D288, D292, D293A, D293E or D293S bases (CSFM Listing No. 7300-0801:161) or separately listed Duct Smoke Detector Housing Model D341 or D342 (CSFM Listing No. 3240-0801:213) or *D340 (CSFM Listing No. 3240-0801:216). Refer to listee's Installation Instructions Manual for details.

XLf: 7271-1062:115

*Rev. 12-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 19, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**